

## Lampiran 6

### Hasil Uji BOD

#### a. Pengujian BOD Reaktor 1

Data ke-	In (mg/L)	Effluent 1 (mg/L)	% Removal
85	127,13	42,38	67%
86	127,13	84,76	33%
87	169,51	127,13	25%
88			
89			
90	127,13	84,76	33%
91			
92			
93			
94	127,13	42,38	67%
95	211,89	84,76	60%
96			

#### b. Pengujian BOD Reaktor 2

Data ke-	In (mg/L)	Effluent 1 (mg/L)	% Removal
85	127,13	42,38	67%
86	127,13	84,76	33%
87	169,51	42,38	75%
88			
89			
90	127,13	42,38	67%
91			
92			
93			
94	127,13	42,38	67%
95	211,89	42,38	80%
96			

a. Kadar BOD tiap kompartemen

<b>Kompartemen</b>	<b>In BOD</b>	<b>Eff BOD</b>	<b>% Removal</b>
1	169,51	127,13	25%
2	127,13	84,76	33%
3	84,76	42,38	50%