

**LAMPIRAN****Lampiran 1. Baku Mutu Air Limbah Domestik**

<b>Parameter</b>	<b>Satuan</b>	<b>Kadar Maksimum*</b>
pH	-	6-9
BOD	mg/L	30
COD	mg/L	100
TSS	mg/L	30
Minyak & Lemak	mg/L	5
Amonia	mg/L	10
Total Coliform	jumlah /100mL	3000
Debit	L/orang/hari	100

*Sumber : PermenLH No.68 Tahun 2016*