



PEMERIKSAAN BERAT ISI GEMBUR AGREGAT HALUS
(SNI 03-4804-1998)

Uraian	Hasil Pengamatan		
	Sampel 1	Sampel 2	Rata-rata
Berat Tabung (W1) gram	11000	11000	11000
Berat Tabung + Agregat SSD (W2) gram	19300	18800	19050
Berat Agregat (W3) gram	8300	7800	8050
Volume Tabung (V) cm ³	5301.438	5301.438	5301.438
Berat Volume Gembur (W3/V) gram/ cm ³	1.566	1.471	1.518

Diperiksa,
Laboran

Darussalam, A.Md.

Disetujui,
Kepala Laboratorium

Ir. Suharyatma, M.T